

Kent



County

Department of Planning Services

Division of Inspection and Enforcement

SARAH KEIFER, AICP
Director

LESLIE H. PERSANS, C.B.O.
Division Head

KENT COUNTY
ADMINISTRATIVE COMPLEX
555 Bay Road
Dover, DE 19901
(Handicapped Accessible)

PHONE 302-744-2452
FAX 302-736-2123
www.co.kent.de.us

December 19, 2008

MI Windows & Doors Inc.
Attn: Michael Rehman
120 Stonebridge Rd.
Dillsburg, PA 17019

RE: Silverline Windows

Dear Sir,

This letter is in response to our recent meeting to discuss MI windows and to determine whether Kent County would approve the windows use to meet requirements of the International Residential Code 2006, Sections R613.2 Window sills and R310.1.4 Operational constraints. It has been determined that the MI windows with the operational stops, do meet the requirements of the above referenced code sections. We would approve their use by Kent County builders. We will require that the two warning stickers (attached) be affixed to the window sash at the time of the final inspection.

If you have any questions or if I can be of any further assistance please feel free to call me at (302) 744-2450, Monday through Friday, 8:00 a.m. until 4:30 p.m.

Sincerely,

Marc A. St. Jean
Permits Coordinator

cc: Leslie H. Persans, C.B.O., Division Head, Assistant Director of Planning Services
Scott Tanner, Inspections Administrator
File