

Laboratory Sample Analysis
A. Total Residual CL_2

Aspects: Chlorination

Frequency: Daily

Record / Documentation: Kent County Wastewater Facilities Plant Samples

Location: Sample: Effluent Comp.
Analysis: Lab

Procedure : Standard Method 4500-Cl-G